



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 770
Sample No. : R308

Date : 13 June 2025

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S Indo Scottish Global School

Address : Ram Maruti Road, Near Talaopali, Thane (W)

E_mail ID : info@indoscotsthane.com;admin@indoscotsthane.com

Date of receiving Sample : 12 June 2025

Sample Collected by : Prabhakar Sonawale

Type of Water Sample : Storage Drinking (3rd Sample)

| Parameters | Results | Limits as per IS 10500 |
|--------------------------------|---------|------------------------|
| pH | 7.20 | 6.5 - 8.5 |
| Free Residual Chlorine | Nil | 1 ppm |
| Turbidity | 2.0 | 5 NTU |
| Chloride | 10.0 | 250 mg/L |
| Total Hardness | 45.0 | 300 mg/L |
| Total Coilform Bacteria (MPN) | 0.00 | 0/100 mL |
| F-Coli | Absent | 0/100 mL |
| E-Coli | Absent | 0/100 mL |

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

13-Jun-25

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

13-Jun-25

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (3rd Sample) Water sample received to our Vakratunda Laboratory on 12/6/2025. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/HQ/PLC/000249/24-25 dated 07.01.2025

This Report has been Signature Digitally.