



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
 चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane, Tel. No. : 26375711

Ref./T.M.C./P.C.C./V.Lab - 3575
 Sample No. : Q1386

Date : 26 March 2025

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S Indo Scottish Global School

Address : Ram Maruti Road, Near Talaopali, Thane (W)

E_mail ID : info@indoscotsthane.com;admin@indoscotsthane.com

Date of receiving Sample : 25 March 2025

Sample Collected by : Prabhakar Sonawale

Type of Water Sample : Storage Drinking (2nd Sample)

Parameters	Results	Limits as per IS 10500
pH	7.20	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	20.0	250 mg/L
Total Hardness	28.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH.

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

26 Mar 25

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

26 Mar 25

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (2nd Sample) Water sample received to our Vakratunda Laboratory on 25/3/2025. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 6380/- vide Receipt No.TMC/HQ/PLC/000249/24-25 dated 07.01.2025

This Report has been Signature Digitally.

Indo Scots Global School

Principal
(Mrs. Nikita Kothari)

